

403.2.2.1

Errata 2021 IBC Chapter 4 SPECIAL DETAILED REQUIREMENTS BASED ON OCCUPANCY AND USE

Code/Standard: 2021 International Building Code

Applies to following Printings: 1st printing

Section/Table/Figure Number: 403.2.2.1

Posted: March 30, 2021

Correction:

[BS] 403.2.2.1 Wall assembly materials—soft body impact. The panels making up the enclosures for *interior exit stairways* and elevator hoistway enclosures shall meet or exceed Soft Body Impact Classification Level 2 as measured by the test method described in ASTM C1629/C1629M when tested from the exterior side of the enclosure.

Correlation Notes: G14-19 AMPC1

403.2.2.2

Errata 2021 IBC Chapter 4 SPECIAL DETAILED REQUIREMENTS BASED ON OCCUPANCY AND USE

Code/Standard: 2021 International Building Code

Applies to following Printings: 1st printing

Section/Table/Figure Number: 403.2.2.2

Posted: March 30, 2021

Correction:

[BS] 403.2.2.2 Wall assembly materials—hard body impact. The panels making up the enclosures for *interior exit stairways* and elevator hoistway enclosures that ~~are~~ is not exposed to the interior of the ~~enclosures for interior exit stairways or elevator hoistway~~ enclosure shall be in accordance with one of the following:

1. The wall assembly shall incorporate not fewer than two layers of impact-resistant panels, each of which meets or exceeds Hard Body Impact Classification Level 2 as measured by the test method described in ASTM C1629/C1629M.
2. The wall assembly shall incorporate not fewer than one layer of impact-resistant panels that meet or exceed Hard Body Impact Classification Level 3 as measured by the test method described in ASTM C1629/C1629M.
3. The wall assembly incorporates multiple layers of any material, tested in tandem, that meets or exceeds Hard Body Impact Classification Level 3 as measured by the test method described in ASTM C1629/C1629M.

Correlation Notes: G14-19 AMPC1

403.2.2.4

Errata	2021 IBC Chapter 14 EXTERIOR WALLS
---------------	---

Code/Standard: 2021 International Building Code

Applies to following Printings: 1st printing

Section/Table/Figure Number: 403.2.2.4

Posted: March 30, 2021

Correction:

[BS] 403.2.2.4 Other wall assemblies. Any other wall assembly that provides impact resistance equivalent to that required by Sections 403.2.2.1 [for Soft Body Impact Classification Level 2](#) and 403.2.2.2 for Hard Body Impact Classification Level 3, as measured by the test method described in ASTM C1629/C1629M, shall be permitted.

Correlation Notes: G14-19 AMPC1

411.3

Errata	2021 IBC Chapter 14 EXTERIOR WALLS
---------------	---

Code/Standard: 2021 International Building Code

Applies to following Printings: 1st printing

Section/Table/Figure Number: 411.3

Posted: March 30, 2021

Correction:

[F]411.3 ~~Fire-alarm-system~~ Automatic smoke detection. Buildings containing *special amusement areas* shall be equipped with an *automatic smoke detection system* in accordance with Section ~~907.2.13~~ 907.2.12.

Correlation Notes: None